CS-4225A (11-05)
(Reproduce Locally)

# GROUND ROD TEST

☐ SIGN LIGHTING

☐ HIGHWAY LIGHTING

| COUNTY | TOWNSHIP | SR & SEC | PROJECT NO. |
|---|---|---|---|
| | | | |

| TEST PERFORMED BY | TEST WITNESSED BY | INSPECTOR-IN-CHARGE |
|---|---|---|
| _____ | _____ | _____ |

*PROVIDE MAXIMUM RESISTANCE OF GROUND ROD TO EARTH LESS THEN TWENTY-FIVE (25) OHMS.*

TEMPERATURE _____ TYPE OF METER _____

SOIL CONDITIONS _____ SOIL CLASSIFICATIONS _____

TAKE GROUND ROD READINGS AT EACH POLE OR STRUCTURE

| DATE | POLE NO. | S.R. | STATION | OHMS | | NUMBER OF RODS | COMMENTS |
|---|---|---|---|---|---|---|---|
| | | | | INITAL | FINAL | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |