



## GROUND ROD TEST

☐ SIGN LIGHTING ☐ HIGHWAY LIGHTING

COUNTY \_\_\_\_\_ TOWNSHIP \_\_\_\_\_

S.R. \_\_\_\_\_ SECT. \_\_\_\_\_ CONTRACT NO. \_\_\_\_\_

TEST PERFORMED BY \_\_\_\_\_

TEST WITNESSED BY \_\_\_\_\_

INSPECTOR IN CHARGE \_\_\_\_\_

TEMPERATURE \_\_\_\_\_ TYPE OF METER \_\_\_\_\_

SOIL CONDITIONS \_\_\_\_\_ SOIL CLASSIFICATIONS \_\_\_\_\_

**PROVIDE MAXIMUM RESISTANCE OF GROUND ROD TO EARTH LESS THEN TWENTY-FIVE (25) OHMS.**

[illegible]